Well Construction Report
WISCONSIN UNIQUE WELL NUMBER DU088

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ABBOTT, SCOTT @ TINA	Phone #: (715)349-5629
Mailing Address: 7107 BARNIKEL RD	
City: SIREN	State: WI — Zip Code: 54872
County: Burnett	Co. Permit #:
Notification #	Completed: 05-18-1998
Well Constructor (Business Name): KENNETH W BEECROFT	Lic. #: 611
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: 162 310TH AVE FREDERIC WI 54837	Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #
Specific Capacity: 1	

1. Well Location

Town of SIREN	Fire # (if avail.): 7107
Street Address or Road Name and Number	
Subdivision Name	Lot # — Block #
Latitude / Longitude in Decimal Degree (DD): 45.7388 °N -92.3517 °W	Method Code: GCD013

NE	NE	Section	Township	Range
or Govt Lot #		33	38 N	16 W

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

WATER

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	55

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 4in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		SAND	Surface	21
		C	S	SANDY CLAY	21	30
		P		HARD PAN	30	37
		S		SAND	37	55

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	NEW BLK A53 10 79 237 BUTT WELD SAWHILL	Surface	51.5
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3	TELESCOPE SS 1I COOK	50.25	55

7. Grout or Other Sealing Material

Method

9. Static Water Level

25 ft. below ground surface

10. Pump Test

Pumping level 35 ft. below surface

Pumping at 10 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

30 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
KB		05-14-1998
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		30	Septic or Holding, or POWTS Tank		35

Comment:

Created On: 06-10-1998 Updated On: 06-30-2020 Review Status: