Well Construction Report
WISCONSIN UNIQUE WELL NUMBER DU089

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: FULNER, RICHARD			Phone #: (715)822-8682
Mailing Address: 2499 10TH			
City: CUMBERLAND	State: WI	Zip Code: 54829	
County: Polk	Co. Permit #:	Notification #:	Completed: 06-11-1997

Well Constructor (Business Name): KENNETH W BEECROFT	Lic. #: 611	Facility ID # (Public Wells):	
Address: 162 310TH AVE FREDERIC WI 54837		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.5	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Fire # (if avail.): 2499

Town of MCKINLEY

Street Address or Road Name and Number: 10TH

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code:

NE or Govt Lot #	NE	Section	Township	Range
		35	36 N	15 W

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
WATER

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	16
4	16	80

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit 8in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
P	HARDPAN	Surface	16
G	GRAVEL	16	22
S	SAND	22	80

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	IPSCO USA A53B 4500 237 NEW BLK BUTT WELD	Surface	76.83
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
3	TELESCOPE WESCO SS 15	75.42	80

7. Grout or Other Sealing Material

Method GRAVITY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY SLURRY	Surface	16	

9. Static Water Level
60 ft. below ground surface

10. Pump Test
Pumping level 70 ft. below surface
Pumping at 5 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
KB		
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		110
Building Drain - Sanitary		60

Type	Qualifier	Distance
Building Overhang		50
Shoreline/Pool		1500
Septic or Holding, or POWTS Tank		100

Comment:

Created On: 07-08-1997 Updated On: 07-08-1997 Review Status: