

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				DU089		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner FULNER, RICHARD						Phone # (715)822-8682		1. Well Location				Fire # (if avail.)	
Mailing Address 2499 10TH						Town of MCKINLEY						2499	
City CUMBERLAND						State WI		Zip Code 54829				Street Address or Road Name and Number 10TH	
County Polk		Co. Permit #		Notification #		Completed 06-11-1997		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) KENNETH W BEECROFT				Lic. # 611		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code	
Address 162 310TH AVE FREDERIC WI 54837				Well Plan Approval #		Approval Date (mm-dd-yyyy)		NE NE Section Township Range or Govt Lot # 35 36 N 15 W		2. Well Type Replacement			
Hicap Permanent Well #		Common Well #		Specific Capacity 0.5		Reason for replaced or reconstructed well ? WATER							
3. Well serves 1 # of Private, potable				Hicap Well ? No		Hicap Property ? No		Construction Type Drilled					
Heat Exchange ___ # of drillholes				Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole Lower Open Bedrock							
8		Surface		16		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 8in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)							
4		16		80									
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
4		IPSCO USA A53B 4500 237 NEW BLK BUTT WELD				Surface		76.83					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
3		TELESCOPE WESCO SS 15				75.42		80					
7. Grout or Other Sealing Material													
Method GRAVITY													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
CLAY SLURRY				Surface		16							
8. Geology													
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
P		HARDPAN				Surface		16					
G		GRAVEL				16		22					
S		SAND				22		80					
9. Static Water Level													
60 ft. below ground surface													
10. Pump Test													
Pumping level 70 ft. below surface													
Pumping at 5 GP M for 1 Hrs.													
Pumping Method ?													
11. Well Is													
12 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed? Yes													
13. Constructor / Supervisory Driller													
Lic #				Date Signed									
KB													
Drill Rig Operator				Lic or Reg #				Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		110	Building Overhang		50
Building Drain - Sanitary		60	Shoreline/Pool		1500
			Septic or Holding, or POWTS Tank		100

Comment:

Created On: 07-08-1997

Updated On: 07-08-1997

Review Status: