Well Construction Report
WISCONSIN UNIQUE WELL NUMBER DU262

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MARK TOLOCKO			Phone #: (414)243-5784
Mailing Address: 12311 N PT WASHINGTN			
City: MEQUON	State: WI	Zip Code: 53092	
County: Ozaukee	Co. Permit #:	Notification #:	Completed: 02-20-1991

1. Well Location
Town of GRAFTON
Fire # (if avail.):
Street Address or Road Name and Number: 525 RIVERBEND RD
Subdivision Name:
Lot #:
Block #:

Well Constructor (Business Name): ROSCHI BROS WELLDRLG AND PUMP IN	Lic. #: 435	Facility ID # (Public Wells):	
Address: 12665 W LISBON RD BROOKFIELD WI 53005		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.5	

Latitude / Longitude in Decimal Degree (DD): 43.2957 °N -87.9355 °W
Method Code: GCD013

SE	SW	Section	Township	Range
or Govt Lot #		30	10 N	22 E

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
NEW CONSTRUCTION
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	106
6	106	197

Upper Enlarged Drillhole / Lower Open Bedrock

Yes — Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C		CLAY	Surface	58
		S	G	SAND @ GRAVEL	58	70
		C	G	STONEY CLAY	70	106
		L		LIMESTONE	106	197

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK STEEL PIPE WELDED JOINTS, 18.97LB ASTM A531780 PSI VALLEY STEEL	Surface	106
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
50 ft. below ground surface

10. Pump Test
Pumping level 72 ft. below surface
Pumping at 10 GP for 1 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE DRILL FLUID	Surface	106	

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
RR		02-20-1991
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
ERW		02-20-1991

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		12	Foundation Drain to Clearwater		13
			Septic or Holding, or POWTS Tank		85

Comment:

Created On: 07-15-1991 Updated On: 07-15-2019 Review Status: