

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				DU274		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner MARK TOLOCKO						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address 506 N PT WASHINGTON						Village of MENOMONEE FALLS									
City GRAFTON						State WI		Zip Code 53204							
County Waukesha		Co. Permit #		Notification #		Completed 02-22-1991		Subdivision Name				Lot # 00003			
Well Constructor (Business Name) ROSCHI BROS WELLDRLG AND PUMP IN				Lic. # 435		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code			
Address 12665 W LISBON RD BROOKFIELD WI 53005				Well Plan Approval #		Approval Date (mm-dd-yyyy)		SE SE		Section 26		Township 8 N		Range 20 E	
								or Govt Lot #							
Hicap Permanent Well #				Common Well #		Specific Capacity 20		2. Well Type New Well							
								of previous unique well # constructed in							
								Reason for replaced or reconstructed well ?							
								Construction Type Drilled							
3. Well serves # of COMMERCIAL Non-community												Hicap Well ? No			
												Hicap Property ? No			
Heat Exchange ___ # of drillholes												Hicap Potable ?			
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
8.75		Surface		95											
6		95		145		Yes Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
C G				STONE CLAY				Surface		68					
P G				HARDPAN/BOULDERS				68		95					
L				LIMESTONE				95		145					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		BLACK STEEL PIPE, WELDED JOINTS, 18.97LB ASTM A531780 PSI VALLEY STEEL				Surface		95							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
BENTONITE DRILL				Surface		95									
9. Static Water Level															
4 ft. below ground surface															
10. Pump Test															
Pumping level 5 ft. below surface															
Pumping at 20 GP for 1.5 Hrs.															
Pumping Method ?															
11. Well Is															
12 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed?															
13. Constructor / Supervisory Driller															
Lic #				Date Signed											
RR				02-21-1991											
Drill Rig Operator				Lic or Reg #				Date Signed							
RR				02-21-1991											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang	>	7	Sewer - Building Sanitary		22
			Septic or Holding, or POWTS Tank	>	55

Comment:

Abandonment Type	Abandonment Date	Procedure	Reason
	06/19/2014	3/4" BENTONITE CHIPS 0-130' 36 SACKS USED	NOT IN USE

Created On: 07-15-1991

Updated On: 07-15-1991

Review Status: