Well Construction Report
WISCONSIN UNIQUE WELL NUMBER DU274

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MARK TOLOCKO	Phone #
Mailing Address: 506 N PT WASHINGTON	
City: GRAFTON	State: WI — Zip Code: 53204
County: Waukesha	Co. Permit #	Notification #	Completed: 02-22-1991
Well Constructor (Business Name): ROSCHI BROS WELLDRLG AND PUMP IN	Lic. #: 435
Address: 12665 W LISBON RD, BROOKFIELD WI 53005	
Hicap Permanent Well #	Common Well #	Specific Capacity: 20

Facility ID # (Public Wells)
Well Plan Approval #
Approval Date (mm-dd-yyyy)

1. Well Location
Village of MENOMONEE FALLS
Fire # (if avail.)
Street Address or Road Name and Number: N57 W14502-44 SHAWN CIRCLE
Subdivision Name | Lot #: 00003 | Block #
Latitude / Longitude in Decimal Degree (DD): °N °W
Method Code

SE	SE	Section	Township	Range
or Govt Lot #		26	8 N	20 E

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves # of COMMERCIAL
Non-community
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	95
6	95	145

Upper Enlarged Drillhole — Lower Open Bedrock

Yes — Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C	G	STONEY CLAY	Surface	68
		P	G	HARDPAN/BOULDERS	68	95
		L		LIMESTONE	95	145

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK STEEL PIPE, WELDED JOINTS, 18.97LB ASTM A531780 PSI VALLEY STEEL	Surface	95
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
4 ft. below ground surface

10. Pump Test
Pumping level 5 ft. below surface
Pumping at 20 GP for 1.5 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE DRILL	Surface	95	

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
RR		02-21-1991
Drill Rig Operator	Lic or Reg #	Date Signed
RR		02-21-1991

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang	>	7	Sewer - Building Sanitary		22
			Septic or Holding, or POWTS Tank	>	55

Comment:

Abandonment Type	Abandonment Date	Procedure	Reason
	06/19/2014	3/4" BENTONITE CHIPS 0-130' 36 SACKS USED	NOT IN USE

Created On: 07-15-1991 Updated On: 07-15-1991 Review Status: