

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				DU275		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner GARY MILEWSKI						Phone # (414)968-5347		1. Well Location				Fire # (if avail.)											
Mailing Address 125 PEMBROOK DR						Town of GENESEE						Street Address or Road Name and Number S23 W30762 BRECON WAY											
City WALES				State WI		Zip Code 53183																	
County Waukesha		Co. Permit #		Notification #		Completed 03-11-1991		Subdivision Name BRECON RIDGE				Lot # 00003		Block #									
Well Constructor (Business Name) ROSCHI BROS WELLDRLG AND PUMP IN				Lic. # 435		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.0021 °N -88.3599 °W				Method Code GCD013									
Address 12665 W LISBON RD BROOKFIELD WI 53005				Well Plan Approval #				NE NW Section Township Range or Govt Lot # 10 6 N 18 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? NEW CONSTRUCTION													
				Approval Date (mm-dd-yyyy)																			
Hicap Permanent Well #				Common Well #		Specific Capacity 0.1				Construction Type Drilled													
3. Well serves 1 # of Private, potable				Hicap Well ? No																			
Heat Exchange ___ # of drillholes				Hicap Property ? No																			
Heat Exchange ___ # of drillholes				Hicap Potable ?																			
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method												8. Geology											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
8.75		Surface		80		Yes Rotary - Mud Circulation				Rotary - Air		S G SAND, GRAVEL, BOULDERS		Surface		26							
6		80		223		Rotary - Air & Foam				Drill-Through Casing Hammer		C G STONEY CLAY		26		80							
						Reverse Rotary				Cable-tool Bit ___ in. dia...		L LIMESTONE		80		174							
						Dual Rotary				Temp. Outer Casing ___ in. dia		H SHALE		174		223							
						Removed? ___ depth ft. (If NO explain on back side)																	
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		15 ft. below ground surface				12 in. above grade									
6		BLACK STEEL PIPE, WELDED JOINTS, 18.97LB ASTM A531780 PSI VALLEY STEEL				Surface		80		10. Pump Test				Developed ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 143 ft. below surface				Disinfected ? Yes									
										Pumping at 7.5 GP for 1.5 Hrs.				Capped ? Yes									
										Pumping Method ?													
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?											
Method												Filled & Sealed Well(s) as needed?											
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement															
BENTONITE DRILL FLUID				Surface		80																	
												13. Constructor / Supervisory Driller				Lic #		Date Signed					
												RR						03-11-1991					
												Drill Rig Operator				Lic or Reg #		Date Signed					
												RR						03-11-1991					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang	>	8	Foundation Drain to Clearwater	>	26

Comment: WELL NOT LOCATED ON HIGHEST POINT OF PROPERTY AS HIGHEST POINT IS TOO FAR FROM HOUSE

Created On: 07-16-1991

Updated On: 07-12-2019

Review Status: