Well Construction Report
WISCONSIN UNIQUE WELL NUMBER DU275

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GARY MILEWSKI			Phone #: (414)968-5347
Mailing Address: 125 PEMBROOK DR			
City: WALES	State: WI	Zip Code: 53183	
County: Waukesha	Co. Permit #:	Notification #:	Completed: 03-11-1991

Well Constructor (Business Name): ROSCHI BROS WELLDRLG AND PUMP IN	Lic. #: 435	Facility ID # (Public Wells):	
Address: 12665 W LISBON RD BROOKFIELD WI 53005		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.1	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of GENESEE

Fire # (if avail.):

Street Address or Road Name and Number: S23 W30762 BRECON WAY

Subdivision Name: BRECON RIDGE	Lot #: 00003	Block #:

Latitude / Longitude in Decimal Degree (DD): 43.0021 °N -88.3599 °W			Method Code: GCD013
NE NW or Govt Lot #	Section: 10	Township: 6 N	Range: 18 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW CONSTRUCTION

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	80
6	80	223

Upper Enlarged Drillhole / Lower Open Bedrock

Yes Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S	G	SAND,GRAVEL,BOULDERS	Surface	26
		C	G	STONEY CLAY	26	80
		L		LIMESTONE	80	174
		H		SHALE	174	223

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK STEEL PIPE, WELDED JOINTS, 18.97LB ASTM A531780 PSI VALLEY STEEL	Surface	80
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
15 ft. below ground surface

10. Pump Test
Pumping level 143 ft. below surface
Pumping at 7.5 GP for 1.5 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE DRILL FLUID	Surface	80	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
RR		03-11-1991
Drill Rig Operator	Lic or Reg #	Date Signed
RR		03-11-1991

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang	>	8	Foundation Drain to Clearwater	>	26

Comment: WELL NOT LOCATED ON HIGHEST POINT OF PROPERTY AS HIGHEST POINT IS TOO FAR FROM HOUSE

Created On: 07-16-1991 Updated On: 07-12-2019 Review Status: