

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				DU472		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner ROGER MEISNER						Phone # (414)684-7452		1. Well Location				Fire # (if avail.)			
Mailing Address 6238 JOHNSON DR						Town of TWO RIVERS						Street Address or Road Name and Number 1313 HWY VV			
City TWO RIVERS				State WI		Zip Code 54241									
County Manitowoc		Co. Permit #		Notification #		Completed 02-28-1991		Subdivision Name			Lot #		Block #		
Well Constructor (Business Name) VAN DE YACHT BILL WATER WELL AND				Lic. # 4462		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.1734 °N -87.6295 °W			Method Code GCD013		
Address 4151 LEDGECREST RD DE PERE WI 54115				Well Plan Approval #				NE SW		Section 28		Township 20 N		Range 24 E	
				Approval Date (mm-dd-yyyy)				or Govt Lot #		28		20 N		24 E	
Hicap Permanent Well #			Common Well #			Specific Capacity 1.5			2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled						
3. Well serves 1 # of Private, potable						Hicap Well ? No									
Heat Exchange ___ # of drillholes						Hicap Property ? No									
Heat Exchange ___ # of drillholes						Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock												
9 Surface 94			Yes Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)												
6 94 121															
8. Geology															
Dia. (in.) From (ft.) To (ft.)			Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.) To (ft.)						
9 Surface 94			C CLAY			CLAY			Surface 28						
6 94 121			G GRAVEL			GRAVEL			28 35						
6 94 121			C CLAY			CLAY			35 75						
6 94 121			G GRAVEL @ BOULDERS			GRAVEL @ BOULDERS			75 94						
6 94 121			L LIME			LIME			94 121						
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 30 ft. below ground surface					
6		NEW BL. STL PL. END WELDED 18.97 .280 A53 SAWHILL				Surface		95							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material										11. Well Is 12 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes					
Method															
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement									
DRILL SLURRY		Surface		94		94		12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? 13. Constructor / Supervisory Driller Lic # Date Signed BV 02-28-1991 Drill Rig Operator Lic or Reg # Date Signed BV 02-28-1991							
Method															
Kind of Sealing Material															
From (ft.)															
To (ft.)															

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	Building Overhang		20
			Septic or Holding, or POWTS Tank		60

Comment:

Created On: 07-15-1991

Updated On: 10-15-2019

Review Status: