

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				DV029		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner ALAN KLUZ						Phone # () 542-6095		1. Well Location				Fire # (if avail.)									
Mailing Address S33 W3137 LONDON DR						Town of GENESEE						Street Address or Road Name and Number S33 W3137 LONDON DR									
City TOWN OF GENESEE				State WI		Zip Code 53127															
County Waukesha		Co. Permit #		Notification #		Completed 03-25-1992		Subdivision Name HARVEST CANYON EST.				Lot # 00010		Block #							
Well Constructor (Business Name) EDDY, ROBERT S				Lic. # 631		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.9821 °N -88.3726 °W				Method Code GCD013							
Address W220 N8318 TOWN LINE MENOMONEE FALLS WI 53051				Well Plan Approval #				SW NE Section Township Range or Govt Lot # 16 6 N 18 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? NEW HOME											
				Approval Date (mm-dd-yyyy)																	
Hicap Permanent Well #				Common Well #		Specific Capacity 1				Construction Type Drilled											
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?																	
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method								8. Geology													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
10		Surface		22		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 10in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 10in. dia <u>Yes</u> Removed? ___depth ft. (If NO explain on back side)				C G		85% CLAY-15% ROCK @ SMALL STONE				Surface		30			
6		22		158						G C		90% GRAVEL - 10% CLAY				30		52			
										L		LIMESTONE				52		135			
										L H		LIMESTONE SHALE				135		158			
6. Casing, Liner, Screen								9. Static Water Level				11. Well Is									
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		20 ft. below ground surface				14 in. above grade							
6		18.97 BLK STEEL WELDED JTS. ASTM A53 LTV				Surface		52		10. Pump Test Pumping level 35 ft. below surface Pumping at 15 GP for 16 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)													
7. Grout or Other Sealing Material								12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? No NONE													
Method GRAVITY																					
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement															
CUTTINGS		Surface		22						13. Constructor / Supervisory Driller				Lic #		Date Signed					
								RSE						03-25-1992							
								Drill Rig Operator						Lic or Reg #		Date Signed					
								RSE						03-25-1992							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Clearwater Sump		50
Building Overhang		12	Foundation Drain to Clearwater		18
			Septic or Holding, or POWTS Tank		80

Comment:

Created On: 04-24-1992

Updated On: 07-09-2019

Review Status: