Well Construction Report
WISCONSIN UNIQUE WELL NUMBER DV030

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: THOMAS ZEIDLER	Phone #: ( )377-2716
Mailing Address: 4043 NORWAY PINE CT	
City: RICHFIELD	State: WI / Zip Code: 53076
County: Washington	Co. Permit #: W05947 / Notification # / Completed: 04-03-1992
Well Constructor (Business Name): EDDY, ROBERT S	Lic. #: 631 / Facility ID # (Public Wells)
Address: W220 N8318 TOWN LINE MENOMONEE FALLS WI 53051	Well Plan Approval # / Approval Date (mm-dd-yyyy)
Hicap Permanent Well # / Common Well #	Specific Capacity

1. Well Location

Town of RICHFIELD

Fire # (if avail.)

Street Address or Road Name and Number: 4043 NORWAY PINE CT

Subdivision Name	Lot #	Block #
WHITE PINE EST.	00019	

Latitude / Longitude in Decimal Degree (DD): 43.2567 °N -88.2385 °W

Method Code: GCD013

NW SW or Govt Lot #	Section	Township	Range
	10	9 N	19 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

NEW HOME

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	22
6	22	53
5	53	56

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit 10in. dia...
- Dual Rotary .....
- Yes Temp. Outer Casing 10in. dia
- Yes Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C	G	95% CLAY - 5% ROCK @ STONE	Surface	30
		G	C	90% GRAVEL - 10% CLAY	30	35
		G	C	90% GRAVEL - 10% CLAY	35	48
		G		GRAVEL	48	56

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	18.97 BLK STEEL WELDED JTS. ASTM A53 U.S. STEEL	Surface	53
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	#20 STAINLESS STEEL	53	56

9. Static Water Level

35 ft. below ground surface

10. Pump Test

Pumping level 35 ft. below surface

Pumping at 15 GP for 18 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method GRAVITY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CUTTINGS	Surface	22	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
RSE		04-06-1992
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
RSE		04-06-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60
Building Overhang		8
Clearwater Sump		75
Foundation Drain to Clearwater		25
Septic or Holding, or POWTS Tank		80

Comment:

Created On: 04-24-1992 Updated On: 07-08-2019 Review Status: