Well Construction Report
WISCONSIN UNIQUE WELL NUMBER DV205

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ED @ ROSEMARY MARTIN	Phone #: (608)362-8777
Mailing Address: 1803 HAPPY HOLLOW RD	
City: JANESVILLE	State: WI — Zip Code: 53545
County: Rock	Co. Permit #: — Notification #: — Completed: 03-15-1991
Well Constructor (Business Name): GOVERT WALTER AND LEON	Lic. #: 658 — Facility ID # (Public Wells):
Address: RT 2 BOX 98 BELOIT WI 53511	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1.7

1. Well Location

Town of ROCK

Fire # (if avail.):

Street Address or Road Name and Number: 1803 HAPPY HOLLOW RD

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): 42.6044 °N -89.04 °W — Method Code: GCD013

NW SE or Govt Lot #: — Section: 26 — Township: 2 N — Range: 12 E

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: INADUCATED WELL PINT

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	50

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		I		TOPSOIL	Surface	3
		C	S	SANDY CLAY	3	20
	N	S		FINE SAND	20	45
		S	G	SAND @ GRAVEL	45	50

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	A53 S. 40 P.E. STEEL 17.97# VENEZULA	Surface	47
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	S.S. SCREEN	47	50

9. Static Water Level

12 ft. below ground surface

10. Pump Test

Pumping level 18 ft. below surface

Pumping at 10 GP for 4 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
WG		03-19-1991
Drill Rig Operator	Lic or Reg #	Date Signed
WG		03-19-1991

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		70
Building Overhang		12
Sewer - Building Sanitary		35
Septic or Holding, or POWTS Tank		50

Comment:

Created On: 07-12-1991 Updated On: 12-09-2019 Review Status: