

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				DV205		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner ED @ ROSEMARY MARTIN						Phone # (608)362-8777		1. Well Location				Fire # (if avail.)		
Mailing Address 1803 HAPPY HOLLOW RD						Town of ROCK						Street Address or Road Name and Number 1803 HAPPY HOLLOW RD		
City JANESVILLE			State WI		Zip Code 53545		Subdivision Name				Lot #		Block #	
County Rock		Co. Permit #		Notification #		Completed 03-15-1991		Latitude / Longitude in Decimal Degree (DD) 42.6044 °N -89.04 °W				Method Code GCD013		
Well Constructor (Business Name) GOVERT WALTER AND LEON				Lic. # 658		Facility ID # (Public Wells)		NW SE Section Township Range or Govt Lot # 26 2 N 12 E		2. Well Type Replacement				
Address RT 2 BOX 98 BELOIT WI 53511				Well Plan Approval #		Approval Date (mm-dd-yyyy)		of previous unique well # constructed in						
Hicap Permanent Well #			Common Well #		Specific Capacity 1.7		Reason for replaced or reconstructed well ? INADUCATED WELL PINT							
3. Well serves 1 # of Private,potable				Hicap Well ? No		Hicap Property ? No		Construction Type Drilled						
Heat Exchange ___ # of drillholes				Hicap Potable ?										
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock					
6		Surface		50		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.)		To (ft.)						
I			TOPSOIL			Surface		3						
C S			SANDY CLAY			3		20						
N S			FINE SAND			20		45						
S G			SAND @ GRAVEL			45		50						
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)						
6		A53 S. 40 P.E. STEEL 17.97# VENEZULA				Surface		47						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
6		S.S. SCREEN				47		50						
7. Grout or Other Sealing Material Method														
9. Static Water Level 12 ft. below ground surface														
10. Pump Test Pumping level 18 ft. below surface Pumping at 10 GP for 4 Hrs. Pumping Method ?														
11. Well Is 12 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes														
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes														
13. Constructor / Supervisory Driller						Lic #		Date Signed						
WG								03-19-1991						
Drill Rig Operator						Lic or Reg #		Date Signed						
WG								03-19-1991						

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		70	Sewer - Building Sanitary		35
Building Overhang		12	Septic or Holding, or POWTS Tank		50

Comment:

Created On: 07-12-1991

Updated On: 12-09-2019

Review Status: