Well Construction Report
WISCONSIN UNIQUE WELL NUMBER DV406

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: EUGENE LEFEBER	Phone #: (414)999-2891
Mailing Address: N8904 WILLOW RD	
City: ST CLOUD	State: WI Zip Code: 53079
County: Fond du Lac	Co. Permit #:
Notification #:	Completed: 06-13-1991
Well Constructor (Business Name): HOWARD E KEIFENHEIM	Lic. #: 251
Facility ID # (Public Wells):	
Address: 782 SECURITY DRIVE, FOND DU LAC WI 54935-8146	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 5	

1. Well Location

Fire # (if avail.):

Town of MARSHFIELD

Street Address or Road Name and Number: HWY 149

Subdivision Name: | Lot #: | Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code:

SW SW or Govt Lot # | Section: 11 | Township: 16 N | Range: 19 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

WELL FOR NEW HOUSE

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	125

Upper Enlarged Drillhole / Lower Open Bedrock

Yes Rotary - Air .....

Rotary - Mud Circulation .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		P		HAND PAN	Surface	5
		S		SAND	5	70
		G	S	SANDY GRAVEL	70	104
		L		WHELL ROCK	104	105
		L		LIMESTONE	105	125

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL 18.97 PE ASTM A-53B WELDED SAWHILL STEELCORP	Surface	105
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

15 ft. below ground surface

10. Pump Test

Pumping level 17 ft. below surface

Pumping at 10 GP for 4 Hrs.

Pumping Method ?

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
MUD SLURRY	Surface	20	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
HK		06-18-1991
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
SDK		06-18-1991

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 10-25-1991 Updated On: 10-25-1991 Review Status: