Well Construction Report
WISCONSIN UNIQUE WELL NUMBER DV409

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JEFF @ CAROL VOELKER			Phone #: (414)999-5846
Mailing Address: RT 1			
City: ST CLOUD	State: WI	Zip Code: 53079	
County: Fond du Lac	Co. Permit #:	Notification #:	Completed: 06-18-1991

Well Constructor (Business Name): HOWARD E KEIFENHEIM	Lic. #: 251	Facility ID # (Public Wells):	
Address: 782 SECURITY DRIVE, FOND DU LAC WI 54935-8146		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.4	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of MARSHFIELD

Fire # (if avail.)

Street Address or Road Name and Number: RT 1

Subdivision Name	Lot #	Block #	
Latitude / Longitude in Decimal Degree (DD): °N °W			Method Code
SE SE or Govt Lot #	Section: 36	Township: 16 N	Range: 19 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW HOME

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	160

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		P	G	HARDPAN @ BOULDERS	Surface	87
		L		LIMESTONE	87	150
	S	L	C	SOFT LIMESTONE @ CLAY	150	160

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL 18.97 PE ASTM A-53B WELDED SAWHILL STEELCORP	Surface	87
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
32 ft. below ground surface

10. Pump Test
Pumping level 55 ft. below surface
Pumping at 10 GP for 2 Hrs.
Pumping Method ?

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
MUD SLURRY	Surface	20	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
HK		06-20-1991
Drill Rig Operator	Lic or Reg #	Date Signed
SK		06-20-1991

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 10-25-1991 Updated On: 10-25-1991 Review Status: