Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EI575

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: LUKAS, WILLIAM	Phone #: (608)635-7532
Mailing Address: N3493 TIPPERARY RD	
City: POYNETTE	State: WI — Zip Code: 53955
County: Columbia	Co. Permit #: — Notification #: — Completed: 11-30-1993
Well Constructor (Business Name): WICKHAMS WATER SERVICE INC	Lic. #: 4540 — Facility ID # (Public Wells):
Address: W10558 HWY J, LODI WI 53555	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1.8

1. Well Location

Town of DEKORRA	Fire # (if avail.): N3493
Street Address or Road Name and Number: N3493 TIPPERARY RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 43.4057 °N -89.5417 °W	Method Code: GCD013
SW NW or Govt Lot #:	Section: 27 — Township: 11 N — Range: 8 E

2. Well Type Replacement

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?
OLD SANDPOINT WENT BAD

Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	110

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 10in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 10in. dia
- Yes — Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
G	GRAVEL	Surface	12
Y	SAND @ GRAVEL	12	40
S	SAND	40	75
N	SANDSTONE	75	110

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLK STEEL 19.45 LBS./FT. A53 .280 WALL VICTORYT@C	Surface	75
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method GRAVITY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PUDDLED CLAY	Surface	20	

9. Static Water Level
45 ft. below ground surface

10. Pump Test
Pumping level 55 ft. below surface
Pumping at 18 GP M for 24 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
MW		12-23-1993
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
RL		12-23-1993

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	Shoreline/Pool		100
Building Overhang		10	Septic or Holding, or POWTS Tank		60

Comment:

Created On: 02-08-1994 Updated On: 04-02-2020 Review Status: