

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EJ015		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner ROGER KLITZKE				Phone # (608)938-4528		1. Well Location				Fire # (if avail.)	
Mailing Address LEGLER VALLEY RD						Town of NEW GLARUS				W6038	
City NEW GLARUS				State WI		Zip Code 53574					
County Green		Co. Permit #		Notification #		Completed 09-20-1991		Subdivision Name		Lot #	
								Block #			
Well Constructor (Business Name) WILLIAM G WEBBER JR				Lic. # 442		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W		Method Code	
Address 21781 HWY 11 W SHULLSBURG WI 53586				Well Plan Approval #		NW NW Section Township Range or Govt Lot # 22 4 N 7 E					
Approval Date (mm-dd-yyyy)											
Hicap Permanent Well #		Common Well #		Specific Capacity		2. Well Type New Well		of previous unique well #		constructed in	
						Reason for replaced or reconstructed well ?		NEW HOUSE			
						Construction Type Drilled					
3. Well serves 1 # of Private,potable				Hicap Well ? No		Hicap Property ? No					
Heat Exchange ___ # of drillholes				Hicap Potable ?							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock			
10		Surface		35							
6		35		130		Rotary - Mud Circulation					
						Rotary - Air					
						Rotary - Air & Foam					
						Drill-Through Casing Hammer					
						Reverse Rotary					
						Cable-tool Bit 10in. dia...					
						Dual Rotary					
						Temp. Outer Casing ___ in. dia					
						Removed? ___ depth ft. (If NO explain on back side)					
8. Geology											
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
L		LIMESTONE		Surface		15					
N		SANDSTONE		15		130					
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly		From (ft.)		To (ft.)					
6		NEW BLK. ST. P.E. 18.97 6.625 .280 WT 398LB A53BE 21		Surface		35					
Dia. (in.)		Screen type, material & slot size		From (ft.)		To (ft.)					
7. Grout or Other Sealing Material											
Method TREMIE PIPE											
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement					
NEAT CEMENT		Surface		35		30					
9. Static Water Level											
75 ft. below ground surface											
10. Pump Test											
Pumping level 75 ft. below surface											
Pumping at 15 GP for 4 Hrs.											
Pumping Method ?											
11. Well Is											
12 in. above grade											
Developed ? Yes											
Disinfected ? Yes											
Capped ? Yes											
12. Notified Owner of need to fill & seal ?											
Filled & Sealed Well(s) as needed? Yes											
13. Constructor / Supervisory Driller											
Lic #		Date Signed									
RLW		09-21-1991									
Drill Rig Operator		Lic or Reg #		Date Signed							
RLW		09-21-1991									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Well Construction	01/02/1992	NON WARNING ISSUED. SHOULD HAVE HAD AN UPPER ENLARGED DRILLHOLE TO 60'.

Created On: 01-21-1992

Updated On: 01-21-1992

Review Status: