Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EJ016

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: EVELYN HOLLIS	Phone #: (608)455-2871
Mailing Address: N8780 SANDY HOOK RD	
City: BROOKLYN	State: WI — Zip Code: 53521
County: Green	Co. Permit #:
Notification #	Completed: 10-02-1991
Well Constructor (Business Name): WILLIAM G WEBBER JR	Lic. #: 442
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: 21781 HWY 11 W, SHULLSBURG WI 53586	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #
Specific Capacity	

1. Well Location

Town of BROOKLYN				Fire # (if avail.): N8780
Street Address or Road Name and Number				
Subdivision Name		Lot #		Block #
Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code
NW or Govt Lot #	NW	Section: 17	Township: 4 N	Range: 9 E

2. Well Type Replacement

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?
NON-CONFORMING

Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	63
6	63	135

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 10in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		I		SOIL	Surface	4
		N		SANDSTONE	4	20
G		H		GREY SHALE	20	25
R		N		RED SANDSTONE	25	70
	X	L	H	MAG. LIMESTONE W/SHALE ST.	70	100
		L		MAG. LIMESTONE	100	115
I		N		WHITE SANDSTONE	115	135

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLK. ST. PE 18.97 SAWHILL USA 6.625 18.97 A53BAPI-5L MADE IN USA TESTED 2660 PSI	Surface	63
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method: TREMIE PIPE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	63	35

9. Static Water Level
63 ft. below ground surface

10. Pump Test
Pumping level 63 ft. below surface
Pumping at 15 GP for 4 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
RLW		10-02-1991
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
RLW		10-02-1991

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75
Building Overhang		20
Animal Yard - Include Hutches		100
Barn Gutter		100
Septic or Holding, or POWTS Tank		50

Comment:

Created On: 12-23-1991 Updated On: 12-23-1991 Review Status: