

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EJ016		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner EVELYN HOLLIS						Phone # (608)455-2871		1. Well Location				Fire # (if avail.)			
Mailing Address N8780 SANDY HOOK RD						Town of BROOKLYN						N8780			
City BROOKLYN						State WI		Zip Code 53521				Street Address or Road Name and Number			
County Green		Co. Permit #		Notification #		Completed 10-02-1991		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) WILLIAM G WEBBER JR				Lic. # 442		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code			
Address 21781 HWY 11 W SHULLSBURG WI 53586				Well Plan Approval #		NW NW Section Township Range or Govt Lot # 17 4 N 9 E		2. Well Type Replacement				of previous unique well # constructed in			
Hicap Permanent Well #		Common Well #		Specific Capacity		Reason for replaced or reconstructed well ? NON-CONFORMING				Construction Type Drilled					
3. Well serves 1 # of Private, potable				Hicap Well ? No		Hicap Property ? No		Heat Exchange ___ # of drillholes				Hicap Potable ?			
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology					
10		Surface		63		Rotary - Mud Circulation		Rotary - Air		Geology Codes					
6		63		135		Rotary - Air & Foam		Drill-Through Casing Hammer		Type, Caving/Noncaving, Color, Hardness, etc...					
						Reverse Rotary				From (ft.)					
						Cable-tool Bit 10in. dia...				To (ft.)					
						Dual Rotary				SOIL Surface 4					
						Temp. Outer Casing ___ in. dia				SANDSTONE 4 20					
						Removed? ___ depth ft. (If NO explain on back side)				GREY SHALE 20 25					
										RED SANDSTONE 25 70					
										MAG. LIMESTONE W/SHALE ST. 70 100					
										MAG. LIMESTONE 100 115					
										WHITE SANDSTONE 115 135					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level					
6		NEW BLK. ST. PE 18.97 SAWHILL USA 6.625 18.97 A53BAPI-5L MADE IN USA TESTED 2660 PSI				Surface		63		63 ft. below ground surface					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is					
										12 in. above grade					
										Developed ? Yes					
										Disinfected ? Yes					
										Capped ? Yes					
7. Grout or Other Sealing Material															
Method TREMIE PIPE															
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ?							
NEAT CEMENT		Surface		63		35		Filled & Sealed Well(s) as needed? Yes							
13. Constructor / Supervisory Driller															
Lic #		Date Signed													
RLW		10-02-1991													
Drill Rig Operator															
Lic or Reg #		Date Signed													
RLW		10-02-1991													

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Animal Yard - Include Hutches		100
Building Overhang		20	Barn Gutter		100
			Septic or Holding, or POWTS Tank		50

Comment:

Created On: 12-23-1991

Updated On: 12-23-1991

Review Status: