

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EJ018		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner ROGER ZURFLUH						Phone # (608)938-4426		1. Well Location				Fire # (if avail.)							
Mailing Address N6404 RIVER RD						Town of MT PLEASANT						N6404							
City MONTICELLO						State WI		Zip Code 53570				Street Address or Road Name and Number RIVER RD							
County Green		Co. Permit #		Notification #		Completed 10-24-1991		Subdivision Name				Lot # Block #							
Well Constructor (Business Name) WILLIAM G WEBBER JR				Lic. # 442		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.7379 °N -89.5607 °W				Method Code GCD013					
Address 21781 HWY 11 W SHULLSBURG WI 53586				Well Plan Approval #		NE SE Section Township Range or Govt Lot # 16 3 N 8 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? NEW DWELLING				Construction Type Drilled							
Hicap Permanent Well #				Common Well #		Specific Capacity													
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
10		Surface		63		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 10in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				C		CLAY		Surface		3			
6		63		200						G		BOULDERS		3		8			
								Y		L		YELLOW LIMESTONE		8		35			
								G		L		GREY LIMESTONE		35		40			
								T		L		BRN. LIMESTONE		40		121			
								Y		N		YELLOW SANDSTONE		121		165			
								I		N		WHITE SANDSTONE		165		185			
								R		N		RED SANDSTONE		185		200			
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		160 ft. below ground surface				12 in. above grade					
6		NEW BLK. ST. PE 18.97 SAWHILL USA 6.625 A53B API5L 2660 PSI				Surface		63		10. Pump Test Pumping level 160 ft. below surface Pumping at 15 GP for 4 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)											
7. Grout or Other Sealing Material Method TREMIE PIPE												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement											
NEAT CEMENT				Surface		63		35											
												13. Constructor / Supervisory Driller Lic # Date Signed GWG Drill Rig Operator Lic or Reg # Date Signed GWG							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		5

Comment:

Created On: 01-09-1992

Updated On: 01-21-2020

Review Status: