Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EJ067

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HARRY HANSON	Phone #: (608)269-7722
Mailing Address: RR 5 BOX 124	
City: SPARTA	State: WI — Zip Code: 54656
County: Monroe	Co. Permit #: — Notification #: — Completed: 05-17-1991
Well Constructor (Business Name): MICHAEL D BEINBORN	Lic. #: 75 — Facility ID # (Public Wells):
Address: 501 E OAK ST, BOSCOBEL WI 53805-1434	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.2

1. Well Location

Town of SPARTA

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

NW SE or Govt Lot #: — Section: 21 — Township: 17 N — Range: 4 W

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?

NEW HOME

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	63
6	63	100

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 10in. dia
- Yes — Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		I		DIRT	Surface	5
	S	S		LOOSE SAND	5	17
	S	N		SOFT SANDROCK	17	54
	H	N		HARD SANDROCK	54	100

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL PLAIN END SAWHILL USA A53B 6X21#18.97	Surface	63
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

33 ft. below ground surface

10. Pump Test

Pumping level 80 ft. below surface

Pumping at 10 GP for 2 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method TREMIE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	63	18

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
SAA		06-18-1991
Drill Rig Operator	Lic or Reg #	Date Signed
SAA		06-18-1991

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		65	Building Overhang		10
			Septic or Holding, or POWTS Tank		40

Comment:

Created On: 10-16-1991 Updated On: 05-24-2016 Review Status: