

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EJ067		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner HARRY HANSON						Phone # (608)269-7722		1. Well Location				Fire # (if avail.)	
Mailing Address RR 5 BOX 124						Town of SPARTA							
City SPARTA						State WI		Zip Code 54656					
County Monroe		Co. Permit #		Notification #		Completed 05-17-1991		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) MICHAEL D BEINBORN				Lic. # 75		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code	
Address 501 E OAK ST BOSCOBEL WI 53805-1434				Well Plan Approval #		NW SE Section Township Range or Govt Lot # 21 17 N 4 W		2. Well Type New Well				of previous unique well # constructed in	
Hicap Permanent Well #		Common Well #		Specific Capacity 0.2		Reason for replaced or reconstructed well ? NEW HOME							
3. Well serves 1 # of Private, potable				Hicap Well ? No		Construction Type Drilled							
Heat Exchange ___ # of drillholes				Hicap Property ? No									
				Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock			
10		Surface		63									
6		63		100		Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 10in. dia <u>Yes</u> Removed? ___ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
		DIRT				Surface		5					
S S		LOOSE SAND				5		17					
S N		SOFT SANDROCK				17		54					
H N		HARD SANDROCK				54		100					
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		NEW BLACK STEEL PLAIN END SAWHILL USA A53B 6X21#18.97				Surface		63					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
7. Grout or Other Sealing Material													
Method TREMIE													
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement							
NEAT CEMENT		Surface		63		18							
9. Static Water Level													
33 ft. below ground surface													
10. Pump Test													
Pumping level 80 ft. below surface													
Pumping at 10 GP for 2 Hrs.													
Pumping Method ?													
11. Well Is													
12 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed? Yes													
13. Constructor / Supervisory Driller													
Lic # Date Signed													
SAA 06-18-1991													
Drill Rig Operator													
Lic or Reg # Date Signed													
SAA 06-18-1991													

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		65	Building Overhang		10
			Septic or Holding, or POWTS Tank		40

Comment:

Created On: 10-16-1991

Updated On: 05-24-2016

Review Status: