

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EJ272		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner FRED LIETHEN					Phone # (414)739-6660		1. Well Location				Fire # (if avail.)			
Mailing Address 2400 STROEBE ISL DR					Town of GRAND CHUTE									
City APPLETON					State WI		Zip Code 54915					Street Address or Road Name and Number HWY JJ		
County Outagamie		Co. Permit #		Notification #		Completed 12-23-1991		Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) LEONARD WILLEMS JR				Lic. # 451		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code			
Address 7962 ST PATS CHURCH GREENLEAF WI 54126-9611				Well Plan Approval #		Approval Date (mm-dd-yyyy)		NE NE Section Township Range		or Govt Lot # 9 21 N 17 E				
Hicap Permanent Well #		Common Well #		Specific Capacity 1		2. Well Type New Well of previous unique well # constructed in								
3. Well serves 1 # of WAREHOUSE Private, potable Heat Exchange ____ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?		Reason for replaced or reconstructed well ? WAREHOUSE @ OFFICE Construction Type Drilled						
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock						
10		Surface		41		Yes Rotary - Mud Circulation								
6		41		120		Yes Rotary - Air								
						Rotary - Air & Foam								
						Drill-Through Casing Hammer								
						Reverse Rotary								
						Cable-tool Bit ____ in. dia...								
						Dual Rotary								
						Temp. Outer Casing ____ in. dia								
						Removed? ____ depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)						
Y		SAND, GRAVEL				Surface		16						
L		LIMESTONE				16		96						
N		SANDSTONE				96		120						
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)						
6		ASTM A-53 GR. B SAWHILL TUBULAR WELDED JOINT WT.18.97 PER FT.				Surface		42						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
7. Grout or Other Sealing Material														
Method PRESSURE GROUT														
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement								
CEMENT		Surface		41		12								
9. Static Water Level 70 ft. below ground surface														
10. Pump Test Pumping level 110 ft. below surface Pumping at 40 GP for 4 Hrs. Pumping Method ?														
11. Well Is 12 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes														
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?														
13. Constructor / Supervisory Driller						Lic #		Date Signed						
LJW								12-27-1991						
Drill Rig Operator						Lic or Reg #		Date Signed						
TW								12-27-1991						

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Building Overhang		6
			Septic or Holding, or POWTS Tank		75

Comment:

Created On: 03-18-1992

Updated On: 10-24-2002

Review Status: