Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EJ274

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: BARRY MINOR	Phone #: (414)532-4657
Mailing Address: 217 SHORT	
City: WRIGHTSTOWN	State: WI — Zip Code: 54180
County: Brown	Co. Permit #: — Notification #: — Completed: 12-30-1991
Well Constructor (Business Name): LEONARD WILLEMS JR	Lic. #: 451 — Facility ID # (Public Wells):
Address: 7962 ST PATS CHURCH GREENLEAF WI 54126-9611	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.3

1. Well Location

Town of WRIGHTSTOWN

Fire # (if avail.):

Street Address or Road Name and Number: AMOS @ MARY CT

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

NW or Govt Lot #	SW	Section	Township	Range
		25	22 N	19 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: NEW HOME

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	116
6	116	316

Upper Enlarged Drillhole — Lower Open Bedrock

Yes Rotary - Mud Circulation .....

Yes Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
C	CLAY	Surface	104
P	HARD PAN	104	116
L	LIMESTONE	116	297
N	SANDSTONE	297	304
L	LIMESTONE	304	316

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A-53 GR. B SAWHILL TUBULAR WELDED JOINT WT.18.97 PER FT.	Surface	117
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

90 ft. below ground surface

10. Pump Test

Pumping level 200 ft. below surface

Pumping at 30 GP for 4 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILLING MUD	Surface	116	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
LJW		01-15-1992
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
TW		01-15-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Building Overhang		11
			Septic or Holding, or POWTS Tank		60

Comment:

Created On: 03-05-1992 Updated On: 03-05-1992 Review Status: