Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EJ275

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: TERRY HEISE			Phone #: (414)799-5940
Mailing Address: WOODLEY LN			
City: KAUKAUNA	State: WI	Zip Code: 54130	
County: Outagamie	Co. Permit #:	Notification #:	Completed: 01-07-1992

Well Constructor (Business Name): LEONARD WILLEMS JR	Lic. #: 451	Facility ID # (Public Wells):	
Address: 7962 ST PATS CHURCH GREENLEAF WI 54126-9611		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.1	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of BUCHANAN

Fire # (if avail.):

Street Address or Road Name and Number: N1069 WOODLEY LN

Subdivision Name:	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W
Method Code:

NE SW or Govt Lot #:	Section: 19	Township: 21 N	Range: 19 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW HOME

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	116
6	116	481

Upper Enlarged Drillhole / Lower Open Bedrock

Yes Rotary - Mud Circulation .....
Yes Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
C	CLAY	Surface	106
L	LIMESTONE	106	481

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A-53 GR. B SAWHILL TUBULAR WELDED JOINT WT.18.97 PER FT.	Surface	117
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
130 ft. below ground surface

10. Pump Test
Pumping level 350 ft. below surface
Pumping at 20 GP for 4 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method PRESSURE GROUT

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CEMENT	Surface	116	10

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
LJW		01-15-1992
Drill Rig Operator	Lic or Reg #	Date Signed
TW		01-15-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100

Type	Qualifier	Distance
Building Overhang		12
Septic or Holding, or POWTS Tank		50

Comment:

Created On: 03-05-1992 Updated On: 03-05-1992 Review Status: