Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EJ824

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JAMES SIMONS	Phone #
Mailing Address: 1035 MADISON AVE	
City: HOWARDS GROVE	State: WI — Zip Code: 53083
County: Sheboygan	Co. Permit #	Notification #	Completed: 03-30-1992

1. Well Location
Village of HOWARDS GROVE
Fire # (if avail.)
Street Address or Road Name and Number: 1035 MADISON AVE
Subdivision Name | Lot # | Block #

Well Constructor (Business Name): FRITSCH, ERWIN W	Lic. #: 397	Facility ID # (Public Wells)
Address: 2337 CTH KK SHEBOYGAN WI 53081		Well Plan Approval #
		Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.7

Latitude / Longitude in Decimal Degree (DD): 43.8406 °N -87.8291 °W — Method Code: GCD013

NE	SW	Section	Township	Range
or Govt Lot #		23	16 N	22 E

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
NEW HOME
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	208

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 10in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
C	CLAY	Surface	10
S	SAND	10	22
C	CLAY	22	125
S	SAND	125	148
P	HARDPAN	148	184
L	LIMESTONE ROCK	184	208

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL PIPE T@C 19.45 .280 ASTM A-53SAWHILL	Surface	184
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
6 ft. below ground surface

10. Pump Test
Pumping level 30 ft. below surface
Pumping at 16 GP for 15 Hrs.
Pumping Method ?

11. Well Is
15 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY SLURRY	Surface	20	

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
EWF		04-04-1992
Drill Rig Operator	Lic or Reg #	Date Signed
EWF		04-04-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		39	Collector Sewer - San or Storm		170
Building Overhang		9	Foundation Drain to Clearwater		24
Clearwater Sump		27	Wastewater Sump		31
			Sewer - Building Sanitary		30

Comment:

Created On: 04-27-1992 Updated On: 10-09-2019 Review Status: