

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EJ825		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A																							
Property Owner ROBERT D MEYER						Phone # (414)452-8493		1. Well Location				Fire # (if avail.)																					
Mailing Address N3148 SCHOOL ST						Town of LIMA						Street Address or Road Name and Number N3148 SCHOOL ST																					
City SHEBOYGAN FALLS				State WI		Zip Code 53085																											
County Sheboygan		Co. Permit #		Notification #		Completed 05-01-1992		Subdivision Name			Lot #		Block #																				
Well Constructor (Business Name) FRITSCH, ERWIN W				Lic. # 397		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.654 °N -87.8297 °W				Method Code GCD013																					
Address 2337 CTH KK SHEBOYGAN WI 53081				Well Plan Approval #		SE NW		Section 26		Township 14 N		Range 22 E																					
				Approval Date (mm-dd-yyyy)		or Govt Lot #		26		14 N		22 E																					
Hicap Permanent Well #		Common Well #		Specific Capacity 5.3		2. Well Type New Well																											
3. Well serves 2 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No		of previous unique well # constructed in																									
						Hicap Property ? No																											
Heat Exchange ___ # of drillholes						Hicap Potable ?		Reason for replaced or reconstructed well ? NEW HOME																									
						Construction Type Drilled																											
4. Potential Contamination Sources - ON REVERSE SIDE																																	
5. Drillhole Dimensions and Construction Method																																	
<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th style="width:15%;">Dia. (in.)</th> <th style="width:15%;">From (ft.)</th> <th style="width:15%;">To (ft.)</th> </tr> <tr> <td>10</td> <td>Surface</td> <td>20</td> </tr> <tr> <td>6</td> <td>20</td> <td>159</td> </tr> </table>			Dia. (in.)	From (ft.)	To (ft.)	10	Surface	20	6	20	159	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th style="width:40%;">Upper Enlarged Drillhole</th> <th style="width:40%;">Lower Open Bedrock</th> </tr> <tr> <td colspan="2"> Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit 10in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side) </td> </tr> </table>											Upper Enlarged Drillhole	Lower Open Bedrock	Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit 10in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)								
Dia. (in.)	From (ft.)	To (ft.)																															
10	Surface	20																															
6	20	159																															
Upper Enlarged Drillhole	Lower Open Bedrock																																
Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit 10in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)																																	
8. Geology																																	
<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th style="width:10%;">Geology Codes</th> <th style="width:50%;">Type, Caving/Noncaving, Color, Hardness, etc...</th> <th style="width:15%;">From (ft.)</th> <th style="width:15%;">To (ft.)</th> </tr> <tr> <td>C</td> <td>CLAY</td> <td>Surface</td> <td>38</td> </tr> <tr> <td>S</td> <td>SAND</td> <td>38</td> <td>90</td> </tr> <tr> <td>P</td> <td>HARD PAN</td> <td>90</td> <td>113</td> </tr> <tr> <td>L</td> <td>LIMESTONE ROCK</td> <td>113</td> <td>159</td> </tr> </table>				Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)	C	CLAY	Surface	38	S	SAND	38	90	P	HARD PAN	90	113	L	LIMESTONE ROCK	113	159										
Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)																														
C	CLAY	Surface	38																														
S	SAND	38	90																														
P	HARD PAN	90	113																														
L	LIMESTONE ROCK	113	159																														
6. Casing, Liner, Screen																																	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		11. Well Is 15 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes																							
6		NEW BLACK STEEL PIPE T@C 19.45 .280 ASTM -A53SAWHILL				Surface		113																									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		9. Static Water Level 17 ft. below ground surface 10. Pump Test Pumping level 20 ft. below surface Pumping at 16 GP for 12 Hrs. Pumping Method ?																							
7. Grout or Other Sealing Material																																	
Method																																	
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?																							
CLAY SLURRY				Surface		20																											
13. Constructor / Supervisory Driller																																	
EWF																																	
Lic #																																	
05-11-1992																																	
Date Signed																																	
05-11-1992																																	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		52	Collector Sewer - San or Storm		52
Building Overhang		16	Downspout/Yard Hydrant		19
Clearwater Sump		80	Foundation Drain to Clearwater		22
			Sewer - Building Sanitary		32

Comment:

Created On: 06-01-1992

Updated On: 10-09-2019

Review Status: