Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EJ825

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ROBERT D MEYER	Phone #: (414)452-8493
Mailing Address: N3148 SCHOOL ST	
City: SHEBOYGAN FALLS	State: WI Zip Code: 53085
County: Sheboygan	Co. Permit #:
Notification #:	Completed: 05-01-1992
Well Constructor (Business Name): FRITSCH, ERWIN W	Lic. #: 397
Facility ID # (Public Wells):	
Address: 2337 CTH KK SHEBOYGAN WI 53081	Well Plan Approval #:
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 5.3	

1. Well Location

Fire # (if avail.):

Town of LIMA

Street Address or Road Name and Number: N3148 SCHOOL ST

Subdivision Name: | Lot #: | Block #:

Latitude / Longitude in Decimal Degree (DD): 43.654 °N -87.8297 °W

Method Code: GCD013

SE NW or Govt Lot #: | Section: 26 | Township: 14 N | Range: 22 E

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?: NEW HOME

Construction Type: Drilled

3. Well serves 2 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	159

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit 10in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
C	CLAY	Surface	38
S	SAND	38	90
P	HARD PAN	90	113
L	LIMESTONE ROCK	113	159

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL PIPE T@C 19.45 .280 ASTM -A53SAWHILL	Surface	113
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

17 ft. below ground surface

10. Pump Test

Pumping level 20 ft. below surface

Pumping at 16 GP for 12 Hrs.

Pumping Method ?

11. Well Is

15 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY SLURRY	Surface	20	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
EWF		05-11-1992
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
EWF		05-11-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		52	Collector Sewer - San or Storm		52
Building Overhang		16	Downspout/Yard Hydrant		19
Clearwater Sump		80	Foundation Drain to Clearwater		22
			Sewer - Building Sanitary		32

Comment:

Created On: 06-01-1992 Updated On: 10-09-2019 Review Status: