

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EK176		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner RICHARD KEENE						Phone # (608)763-2267		1. Well Location				Fire # (if avail.)									
Mailing Address RT 1						Town of POTOSI															
City POTOSI						State WI		Zip Code 53820													
County		Co. Permit #		Notification #		Completed 05-15-1992		Subdivision Name				Lot #		Block #							
Well Constructor (Business Name) FAHERTY, FRANCIS X						Lic. # 5824		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)		Method Code							
Address PO BOX 247 PLATTEVILLE WI 53818-0247						Well Plan Approval #		°N		°W											
								NW SW		Section 14		Township 3 N		Range 3 W							
Hicap Permanent Well #						Common Well #		Specific Capacity 0.8				2. Well Type Replacement		of previous unique well #		constructed in					
Heat Exchange ___ # of drillholes						Hicap Well ? No		Hicap Property ? No				Reason for replaced or reconstructed well ?		OLD WELL WEAK							
3. Well serves # of STOCK WELL						Hicap Potable ?		Construction Type Drilled													
Private, potable																					
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
10		Surface		62		Rotary - Mud Circulation						C		CLAY		Surface		10			
6		62		123		<u>Yes</u> Rotary - Air						L		GALENA LIMESTONE		10		123			
Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)																					
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		20 ft. below ground surface				12 in. above grade							
6		A-53 19.45#FT. V.S.P. T@C				Surface		62		10. Pump Test				Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 50 ft. below surface				Disinfected ? Yes							
										Pumping at 25 GP for 0.5 Hrs.				Capped ? Yes							
										Pumping Method ?											
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?							
Method PRES. PUMPED														Filled & Sealed Well(s) as needed?							
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement															
PORTLAND TYPE 1		Surface		62		25															
														13. Constructor / Supervisory Driller				Lic #		Date Signed	
														FXF				05-17-1992			
														Drill Rig Operator		Lic or Reg #		Date Signed			
														JF				05-16-1992			

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 06-24-1992

Updated On: 06-24-1992

Review Status: