

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EK177		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner FRANK RICHARD						Phone # (608)568-3418		1. Well Location				Fire # (if avail.)											
Mailing Address 3411 BUSCH LN						Town of JAMESTOWN																	
City DICKEYVILLE						State WI		Zip Code 53808															
County Grant		Co. Permit #		Notification #		Completed 05-22-1992		Subdivision Name				Lot # Block #											
Well Constructor (Business Name) FAHERTY, FRANCIS X				Lic. # 5824		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code											
Address PO BOX 247 PLATTEVILLE WI 53818-0247				Well Plan Approval #		Approval Date (mm-dd-yyyy)		°N °W		Range													
Hicap Permanent Well #		Common Well #		Specific Capacity 0.9		NW NE Section Township Range or Govt Lot # 4 1 N 2 W		2. Well Type New Well				of previous unique well # constructed in											
Reason for replaced or reconstructed well ?				NEW HOUSE																			
3. Well serves 1 # of Private, potable				Hicap Well ? No		Hicap Property ? No		Construction Type Drilled															
Heat Exchange ___ # of drillholes				Hicap Potable ?																			
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method														8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
10		Surface		122		Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)						CLAY		Surface		15							
6		122		283								L		GALENA LIMESTONE		15		148					
												L		UPPER PLATTEVILLE LIMESTONE		148		182					
												L		TRENTON MCGREGOR LIMESTONE		182		237					
												N		ST. PETER SANDSTONE		237		283					
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		203 ft. below ground surface				12 in. above grade									
6		A-53 19.45#/FT. V.S.P. T@C				Surface		122		10. Pump Test				Developed ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 220 ft. below surface				Disinfected ? Yes									
										Pumping at 15 GP for 0.5 Hrs.				Capped ? Yes									
										Pumping Method ?													
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?									
Method PRESSURE PUMPED																							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?													
PORTLAND TYPE 1				Surface		122		75															
13. Constructor / Supervisory Driller								Lic #		Date Signed													
FXF										05-25-1992													
Drill Rig Operator								Lic or Reg #		Date Signed													
JF										05-25-1992													

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 06-24-1992

Updated On: 06-24-1992

Review Status: