Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EK177

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: FRANK RICHARD			Phone #: (608)568-3418
Mailing Address: 3411 BUSCH LN			
City: DICKEYVILLE	State: WI	Zip Code: 53808	
County: Grant	Co. Permit #:	Notification #:	Completed: 05-22-1992

1. Well Location

Town of JAMESTOWN

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name: | Lot #: | Block #:

Well Constructor (Business Name): FAHERTY, FRANCIS X	Lic. #: 5824	Facility ID # (Public Wells):	Latitude / Longitude in Decimal Degree (DD): °N °W	Method Code:
Address: PO BOX 247 PLATTEVILLE WI 53818-0247		Well Plan Approval #:	NW NE or Govt Lot #:	Section: 4
		Approval Date (mm-dd-yyyy):	Township: 1 N	Range: 2 W

2. Well Type New Well

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?

NEW HOUSE

Construction Type: Drilled

3. Well serves 1 # of	Hicap Well ? No	Heat Exchange____# of drillholes
Private,potable	Hicap Property ? No	
	Hicap Potable ?	

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	122
6	122	283

Upper Enlarged Drillhole / Lower Open Bedrock

Yes — Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
C	CLAY	Surface	15
L	GALENA LIMESTONE	15	148
L	UPPER PLATTEVILLE LIMESTONE	148	182
L	TRENTON MCGREGOR LIMESTONE	182	237
N	ST. PETER SANDSTONE	237	283

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	A-53 19.45#/FT. V.S.P. T@C	Surface	122
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

203 ft. below ground surface

10. Pump Test

Pumping level 220 ft. below surface

Pumping at 15 GP for 0.5 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method PRESSURE PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PORTLAND TYPE 1	Surface	122	75

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
FXF		05-25-1992
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JF		05-25-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 06-24-1992 Updated On: 06-24-1992 Review Status: