

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EK322		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner GARY SARAPHINE						Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address N72 W23272 GOOD HOPE						Town of SPRINGFIELD							
City SUSSEX						State WI		Zip Code 53089					
County Marquette		Co. Permit #		Notification #		Completed 05-28-1992		Street Address or Road Name and Number DOVAR CT					
						Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) ROOS, THOMAS D				Lic. # 249		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code	
Address PO BOX 82 OXFORD WI 53952-0082						Well Plan Approval #		SW NE Section Township Range or Govt Lot # 12 17 N 8 E					
						Approval Date (mm-dd-yyyy)		2. Well Type New Well					
Hicap Permanent Well #				Common Well #		Specific Capacity		of previous unique well # constructed in					
								Reason for replaced or reconstructed well ? NEW HOME					
3. Well serves 1 # of				Hicap Well ? No									
Private, potable				Hicap Property ? No									
Heat Exchange ___ # of drillholes				Hicap Potable ?				Construction Type Drilled					
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock				
5		Surface		161									
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.)		To (ft.)		
			S G SAND @ LIGHT GRAVEL						Surface		161		
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
5		SAWHILL PE WELD A53B WT 14.62 PSI 1780				Surface		158					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
5		3' JOHNSON SS 10 SLOT				158		161					
7. Grout or Other Sealing Material Method													
9. Static Water Level 77 ft. below ground surface													
10. Pump Test Pumping level 77 ft. below surface Pumping at 15 GP for 24 Hrs. Pumping Method ?													
11. Well Is 16 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes													
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?													
13. Constructor / Supervisory Driller								Lic #		Date Signed			
TDR										06-10-1992			
Drill Rig Operator								Lic or Reg #		Date Signed			
TDR										06-10-1992			

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		12

Comment:

Created On: 06-24-1992

Updated On: 06-24-1992

Review Status: