Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EL444

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JUNIOR BATEMAN	Phone #: (715)723-7854
Mailing Address: 17815 W LAFAYETTE DR	
City: CHIPPEWA FALLS	State: WI — Zip Code: 54729

County	Co. Permit #	Notification #	Completed
Chippewa	W06152		05-26-1992

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
PEAK, VERN	14	

Address: RT 3 BOX 215
CADOTT WI 54727-9114

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

Hicap Permanent Well #	Common Well #	Specific Capacity
		2

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of LAFAYETTE

Fire # (if avail.):

Street Address or Road Name and Number: HEMLOCK DR

Subdivision Name	Lot #	Block #
WISSOTA SOUTH	00010	

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code:

SW SW or Govt Lot #	Section	Township	Range
	11	28 N	8 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW HOME

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	39.58

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
S	SAND	Surface	39.58

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL-18.97-A53B U.S. (SAWHILL) P.E.-WELDED	Surface	36
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
4	COOK-STAINLESS 12 SLOT	36	39.58

7. Grout or Other Sealing Material

Method

9. Static Water Level

20 ft. below ground surface

10. Pump Test

Pumping level 27.4 ft. below surface

Pumping at 15 GP for 2 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
VP		05-26-1992
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
VP		05-26-1992

4a. Potential Contamination Sources Is the well located in floodplain ?

Comment:

Created On: 06-24-1992 Updated On: 06-24-1992 Review Status: