Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EL444

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner	JUNIOR BATEMAN
Phone #	(715)723-7854
Mailing Address	17815 W LAFAYETTE DR
City	CHIPPEWA FALLS
State	WI
Zip Code	54729
County	Chippewa
Co. Permit #	W06152
Notification #	
Completed	05-26-1992
Well Constructor (Business Name)	PEAK, VERN
Lic. #	14
Facility ID # (Public Wells)	
Well Plan Approval #	
Address	RT 3 BOX 215 CADOTT WI 54727-9114
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	
Common Well #	
Specific Capacity	2

1. Well Location
Town of LAFAYETTE
Fire # (if avail.)
Street Address or Road Name and Number: HEMLOCK DR
Subdivision Name: WISSOTA SOUTH
Lot #: 00010
Block #:
Latitude / Longitude in Decimal Degree (DD): °N °W
Method Code:
SW SW or Govt Lot #
Section: 11
Township: 28 N
Range: 8 W

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
NEW HOME
Construction Type Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	39.58

Upper Enlarged Drillhole
Lower Open Bedrock
Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		SAND	Surface	39.58

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL-18.97-A53B U.S. (SAWHILL) P.E.-WELDED	Surface	36

Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	COOK-STAINLESS 12 SLOT	36	39.58

9. Static Water Level
20 ft. below ground surface

10. Pump Test
Pumping level 27.4 ft. below surface
Pumping at 15 GP for 2 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
VP		05-26-1992
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
VP		05-26-1992

4a. Potential Contamination Sources Is the well located in floodplain ?

Comment:

Created On: 06-24-1992 Updated On: 06-24-1992 Review Status: