Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EL893

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JACK LINK	Phone #: (800)346-6896
Mailing Address: PO BOX 397	
City: MINONG	State: WI — Zip Code: 54859
County: Washburn	Co. Permit #: — Notification #: — Completed: 04-08-1992
Well Constructor (Business Name): BUTTERFIELD, ROSCOE C	Lic. #: 357 — Facility ID # (Public Wells):
Address: RT 3 HAYWARD WI 54843-9803	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.2

1. Well Location

Town of MINONG

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

NW SW or Govt Lot #: — Section: 27 — Township: 42 N — Range: 13 W

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?

WATER

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	134

Upper Enlarged Drillhole — Lower Open Bedrock

Yes Rotary - Air .....

Rotary - Mud Circulation .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	NEW BLACK STEEL, WELDED 10.79#/FT ASTM A-53 BMAVERICK TUBE	Surface	131
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	STAINLESS STEEL	131	134

7. Grout or Other Sealing Material

Method GRAVITY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILL SLURRY	Surface	0	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	S			SAND	Surface	7
W	S			SAND, WATER	7	80
W	S	G		SAND, GRAVEL, WATER	80	85
W	S			SAND, WATER	85	93
W	Z			CLAY, GRAVEL, WATER	93	98
W	S	M		SILT SAND, SAND, WATER	98	118
A	Z			CLAY, GRAVEL, COARSE GRAVEL	118	125
W	S	M		SAND, SILT SAND, WATER	125	128
W	G	C		GRAVEL CLAY WATER	128	134

9. Static Water Level

7 ft. below ground surface

10. Pump Test

Pumping level 60 ft. below surface

Pumping at 12 GP for 1 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
RB		04-20-1992
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		63

Type	Qualifier	Distance
Building Overhang		80
Septic or Holding, or POWTS Tank		110

Comment:

Created On: 06-29-1992 Updated On: 06-29-1992 Review Status: