

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EL893		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner JACK LINK						Phone # (800)346-6896		1. Well Location				Fire # (if avail.)					
Mailing Address PO BOX 397						Town of MINONG											
City MINONG						State WI		Zip Code 54859									
County Washburn		Co. Permit #		Notification #		Completed 04-08-1992		Subdivision Name				Lot #					
												Block #					
Well Constructor (Business Name) BUTTERFIELD, ROSCOE C				Lic. # 357		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code					
Address RT 3 HAYWARD WI 54843-9803				Well Plan Approval #		NW SW Section Township Range or Govt Lot # 27 42 N 13 W											
				Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #		Common Well #		Specific Capacity 0.2													
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? WATER Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method												8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
4		Surface		134										Surface		7	
						Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				W S SAND W S SAND, WATER W S G SAND, GRAVEL, WATER W S SAND, WATER W Z CLAY, GRAVEL, WATER W S M SILT SAND, SAND, WATER A Z CLAY, GRAVEL, COARSE GRAVEL W S M SAND, SILT SAND, WATER W G C GRAVEL CLAY WATER				7 80 85 93 98 118 125 128 134			
6. Casing, Liner, Screen																	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)									
4		NEW BLACK STEEL, WELDED 10.79#/FT ASTM A-53 BMAVERICK TUBE				Surface		131									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
4		STAINLESS STEEL				131		134									
7. Grout or Other Sealing Material																	
Method GRAVITY																	
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement									
DRILL SLURRY				Surface		0											

9. Static Water Level

7 ft. below ground surface

10. Pump Test

Pumping level 60 ft. below surface

Pumping at 12 GP for 1 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

No

NONE

13. Constructor / Supervisory Driller

Lic #

Date Signed

RB

04-20-1992

Drill Rig Operator

Lic or Reg #

Date Signed

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		63	Building Overhang		80
			Septic or Holding, or POWTS Tank		110

Comment:

Created On: 06-29-1992

Updated On: 06-29-1992

Review Status: