Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EL896

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: EUGENE @ SHERRY KASTEN			Phone #: (715)468-7961
Mailing Address: HCR 69 BOX 280			
City: SHELL LAKE	State: WI	Zip Code: 54871	
County: Washburn	Co. Permit #:	Notification #:	Completed: 04-28-1992

Well Constructor (Business Name): BUTTERFIELD, ROSCOE C	Lic. #: 357	Facility ID # (Public Wells):	
Address: RT 3 HAYWARD WI 54843-9803		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 4.5	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of SPOONER

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name:	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): °N °W			Method Code:
SE SW or Govt Lot #:	Section: 34	Township: 39 N	Range: 12 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
WATER

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	123

Upper Enlarged Drillhole / Lower Open Bedrock

Yes Rotary - Air .....
Rotary - Mud Circulation .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		G	S	GRAVEL, SAND, SILT, ROCKS	Surface	50
		C	G	CLAY, GRAVEL	50	72
	A	G	M	COARSE GRAVEL, ROCKS, SILT	72	105
		G	S	GRAVEL, SAND, SILT	105	110
	W	Y		SAND, GRAVEL, WATER	110	123

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	NEW BLACK STEEL, WELDED 10.79#/FT ASTM A-53 BMAVERICK	Surface	120
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	STAINLESS STEEL	120	123

7. Grout or Other Sealing Material
Method GRAVITY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE	Surface	0	

9. Static Water Level
108 ft. below ground surface

10. Pump Test
Pumping level 112 ft. below surface
Pumping at 18 GP for 1 Hrs.
Pumping Method ?

11. Well Is
20 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
RB		06-01-1992
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75

Type	Qualifier	Distance
Building Overhang		22
Septic or Holding, or POWTS Tank		80

Comment:

Created On: 06-19-1992 Updated On: 06-19-1992 Review Status: