

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EL896		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner EUGENE @ SHERRY KASTEN						Phone # (715)468-7961		1. Well Location				Fire # (if avail.)									
Mailing Address HCR 69 BOX 280						Town of SPOONER															
City SHELL LAKE						State WI		Zip Code 54871													
County Washburn		Co. Permit #		Notification #		Completed 04-28-1992		Subdivision Name				Lot # Block #									
Well Constructor (Business Name) BUTTERFIELD, ROSCOE C				Lic. # 357		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code									
Address RT 3 HAYWARD WI 54843-9803				Well Plan Approval #		SE SW Section Township Range or Govt Lot # 34 39 N 12 W															
Approval Date (mm-dd-yyyy)				Hicap Permanent Well #		Common Well #		Specific Capacity 4.5				2. Well Type New Well									
Hicap Property ? No				Hicap Potable ?		Reason for replaced or reconstructed well ? WATER															
3. Well serves 1 # of Private, potable				Heat Exchange ___ # of drillholes		Construction Type Drilled															
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
4		Surface		123		Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)								A G S		GRAVEL, SAND, SILT, ROCKS		Surface		50	
														C G		CLAY, GRAVEL		50		72	
														A G M		COARSE GRAVEL, ROCKS, SILT		72		105	
														G S		GRAVEL, SAND, SILT		105		110	
														W Y		SAND, GRAVEL, WATER		110		123	
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		108 ft. below ground surface				20 in. above grade							
4		NEW BLACK STEEL, WELDED 10.79#/FT ASTM A-53 BMAVERICK				Surface		120		10. Pump Test Pumping level 112 ft. below surface Pumping at 18 GP for 1 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)													
4		STAINLESS STEEL				120		123													
7. Grout or Other Sealing Material Method GRAVITY														12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? No							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement													
BENTONITE				Surface		0															
														13. Constructor / Supervisory Driller				Lic #		Date Signed	
														RB						06-01-1992	
														Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Building Overhang		22
			Septic or Holding, or POWTS Tank		80

Comment:

Created On: 06-19-1992

Updated On: 06-19-1992

Review Status: