Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EL897

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GERALD @ MARGARET DORSCHEID			Phone #: (608)249-9490
Mailing Address: 930 BLAINE DR			
City: MADISON	State: WI	Zip Code: 53704	
County: Sawyer	Co. Permit #:	Notification #:	Completed: 04-29-1992

1. Well Location
Town of OJIBWA
Fire # (if avail.):
Street Address or Road Name and Number:
Subdivision Name: | Lot #: | Block #:

Well Constructor (Business Name): BUTTERFIELD, ROSCOE C	Lic. #: 357	Facility ID # (Public Wells):	Latitude / Longitude in Decimal Degree (DD): °N °W	Method Code:
Address: RT 3 HAYWARD WI 54843-9803		Well Plan Approval #:	NW NE or Govt Lot #:	Section: 35
		Approval Date (mm-dd-yyyy):	Township: 39 N	Range: 6 W

2. Well Type New Well
of previous unique well #: constructed in:
Reason for replaced or reconstructed well ?: WATER

Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	60

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
- Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	A	G	M	COARSE, GRAVEL, SILT, ROCKS	Surface	45
		G	C	GRAVEL, CLAY	45	50
	W	G	S	GRAVEL, SAND, WATER	50	60

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	NEW BLACK STEEL, WELDED 10.79#/FT ASTM A-53BMAVERICK	Surface	57
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	STAINLESS STEEL	57	60

9. Static Water Level
35 ft. below ground surface

10. Pump Test
Pumping level 47 ft. below surface
Pumping at 12 GP for 1 Hrs.
Pumping Method ?

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method GRAVITY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE	Surface	0	

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? No
NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
RB		05-26-1992
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		85	Privy		150

Comment:

Created On: 06-19-1992 Updated On: 06-19-1992 Review Status: