Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EM253

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: EVANS, RICHARD	Phone #: (414)569-9437
Mailing Address: 3467 N RIVERLINE DR	
City: OCONOMOWOC	State: WI — Zip Code: 53006
County: Waukesha	Co. Permit #:
Notification #	Completed: 09-12-1995
Well Constructor (Business Name): LAYNE NORTHWEST COMPANY	Lic. #: 582
Address: W229 N5005 DUPLAINVI PEWAUKEE WI 53072	
Hicap Permanent Well #	Common Well #
Facility ID # (Public Wells)	
Well Plan Approval #	
Approval Date (mm-dd-yyyy)	
Specific Capacity: 10	

1. Well Location

Town of SUMMIT

Fire # (if avail.)

Street Address or Road Name and Number: 3467 N RIVERLINE DR

Subdivision Name: RIVERLINE	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code

NW	SE	Section	Township	Range
or Govt Lot #		7	7 N	17 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?: NEW HOME

Construction Type: Drilled

3. Well serves # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	151

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
S	SAND	Surface	135
Y	SAND @ GRAVEL	135	140
L	LIMESTONE	140	151

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW STEEL PE WELDED A53 SAWHILL 1897	Surface	140
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

30 ft. below ground surface

10. Pump Test

Pumping level 32 ft. below surface

Pumping at 20 GP M for 24 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	0	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
WM		10-12-1995
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
TB		10-12-1995

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Downspout/Yard Hydrant		20
Building Overhang		16	Foundation Drain to Clearwater		16
Clearwater Sump		23	Wastewater Sump		53
			Septic or Holding, or POWTS Tank		75

Comment:

Created On: 06-04-1996 Updated On: 02-23-2018 Review Status: