Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EM345

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: JOHN HALBACK	Phone #: (414)892-4087
Mailing Address: N5503 STEPHEN CT	
City: PLYMOUTH	State: WI — Zip Code: 53073
County: Sheboygan	Co. Permit #: — Notification #: — Completed: 01-03-1992
Well Constructor (Business Name): STEPHAN D KEIFENHEIM	Lic. #: 4225 — Facility ID # (Public Wells):
Address: RT 2 BOX 57 BRILLION WI 54110-9318	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1.5

1. Well Location

Town of GREENBUSH				Fire # (if avail.):
Street Address or Road Name and Number: HWY T				
Subdivision Name:	Lot #:	Block #:		
Latitude / Longitude in Decimal Degree (DD): °N °W				Method Code:
NE SE or Govt Lot #:	Section: 19	Township: 15 N	Range: 20 E	

2. Well Type New Well
of previous unique well #: — constructed in:
Reason for replaced or reconstructed well ?: NEW HOME
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	180

Upper Enlarged Drillhole — Lower Open Bedrock

Yes — Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		G		COBBLES	Surface	23
		S		SAND	23	70
G		C		GRAY CLAY	70	82
		S	G	SAND @ BOULDERS	82	109
		Y		SAND @ GRAVEL	109	123
		L		LIMESTONE	123	180

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL 18:97 P.E. A.S.T.M. A-53B WELDED SAWHILLSTEEL CORP.	Surface	123
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
MUD SLURRY	Surface	20	

9. Static Water Level
70 ft. below ground surface

10. Pump Test
Pumping level 80 ft. below surface
Pumping at 15 GP for 1.5 Hrs.
Pumping Method ?

11. Well Is
20 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
SK		01-04-1992
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
SK		01-04-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 03-09-1992 Updated On: 03-09-1992 Review Status: