Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EM453

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GOOD SHEPARD CHURCH	Phone #: (715)325-3355
Mailing Address: 10611 HWY 13 S	
City: WISCONSIN RAPIDS	State: WI — Zip Code: 54494
County: Wood	Co. Permit #: — Notification #: — Completed: 01-22-1992
Well Constructor (Business Name): BERTRAM JUNEMANN WD INC	Lic. #: 84 — Facility ID # (Public Wells): — Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Address: 7285 CTY TRK S, RUDOLPH WI 54475	
Hicap Permanent Well #: — Common Well #: — Specific Capacity: 6.7	

1. Well Location

Town of SARATOGA

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

NW	SW	Section	Township	Range
or Govt Lot #		16	21 N	6 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?

NEW HOME

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	30

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	SAND @ GRAVEL	Surface	30

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	P.E. A-53- B SAWHILL	Surface	27
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
5.625	OD JOHNSON SS	27	30

9. Static Water Level

15 ft. below ground surface

10. Pump Test

Pumping level 18 ft. below surface

Pumping at 20 GP for 1 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

OWNER WILL

13. Constructor / Supervisory Driller	Lic #	Date Signed
JJ		02-10-1991
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		55
Building Drain - Sanitary		25
Building Overhang		25
Septic or Holding, or POWTS Tank		35

Comment:

Created On: 03-05-1992 Updated On: 03-05-1992 Review Status: