Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EM454

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ADLEE CONST.			Phone #: (715)886-4886
Mailing Address: 740 WATERWORKS RD			
City: NEKOOSA	State: WI	Zip Code: 54457	
County: Adams	Co. Permit #:	Notification #:	Completed: 12-21-1991

Well Constructor (Business Name): BERTRAM JUNEMANN WD INC	Lic. #: 84	Facility ID # (Public Wells):	
Address: 7285 CTY TRK S RUDOLPH WI 54475		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 6.7	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of ROME

Fire # (if avail.):

Street Address or Road Name and Number: 493 16TH LN

Subdivision Name: ARCHER PARK	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): 44.1862 °N -89.8788 °W			Method Code: GCD013
SW SW or Govt Lot #	Section: 22	Township: 20 N	Range: 5 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW HOME

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	39

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	SAND @ GRAVEL	Surface	39

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	P.E. A-53 B 18.97 SAWHILL	Surface	36
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5.625	O.D. JOHNSON SS	36	39

9. Static Water Level
21 ft. below ground surface

10. Pump Test
Pumping level 24 ft. below surface
Pumping at 20 GP for 1 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
JJ		02-05-1992
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60
Building Overhang		5
Shoreline/Pool		150
Wastewater Sump		60
Septic or Holding, or POWTS Tank		60

Comment:

Created On: 03-05-1992 Updated On: 05-04-2020 Review Status: