

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EM464		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner DAVE FRATER						Phone # (715)723-3227		1. Well Location				Fire # (if avail.)							
Mailing Address 1010 S BIRON DR						Town of SARATOGA						Street Address or Road Name and Number TEN MILE AVE							
City WISCONSIN RAPIDS				State WI		Zip Code 54494													
County		Co. Permit #		Notification #		Completed		Subdivision Name			Lot #		Block #						
Wood		12-27-1991		Latitude / Longitude in Decimal Degree (DD)		Method Code		SW NE Section Township Range or Govt Lot # 33 21 N 6 E											
Well Constructor (Business Name) BERTRAM JUNEMANN WD INC				Lic. # 84		Facility ID # (Public Wells)													
Address 7285 CTY TRK S RUDOLPH WI 54475				Well Plan Approval #		Approval Date (mm-dd-yyyy)		2. Well Type New Well											
Hicap Permanent Well #				Common Well #		Specific Capacity 6.7		Reason for replaced or reconstructed well ? NEW HOME											
3. Well serves 1 # of				Hicap Well ? No		Hicap Property ? No		Construction Type Drilled											
Private, potable				Hicap Potable ?		Heat Exchange ___ # of drillholes													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
6		Surface		44		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		S		SAND		Surface		44					
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		25 ft. below ground surface				12 in. above grade					
6		P.E. A-53 18.97 LTV				Surface		41.75		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 28 ft. below surface				Disinfected ? Yes					
5.625		OD. JOHNSON SS				41		44		Pumping at 20 GP for 1 Hrs.				Capped ? Yes					
7. Grout or Other Sealing Material												Pumping Method ?				12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?			
Method												13. Constructor / Supervisory Driller							
JJ												Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		90	Building Overhang		60
			Septic or Holding, or POWTS Tank		75

Comment:

Created On: 03-05-1992

Updated On: 03-05-1992

Review Status: