Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EM909

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DALE SANFORD			Phone #
Mailing Address: HC 1 BOX 444			
City: FLORENCE	State: WI	Zip Code: 54121	
County: Florence	Co. Permit #	Notification #	Completed: 01-22-1992

Well Constructor (Business Name): ROMITTI JR, PETER	Lic. # 466	Facility ID # (Public Wells)	
Address: W8859 CNTY N NIAGARA WI 54151-9788		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.7	

1. Well Location

Town of FLORENCE

Fire # (if avail.)

Street Address or Road Name and Number

Subdivision Name	Lot #	Block #	
Latitude / Longitude in Decimal Degree (DD): °N °W			Method Code
SE SW or Govt Lot #	Section: 26	Township: 39 N	Range: 18 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	185

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		SAND	Surface	30
		Y		SAND, GRAVEL	30	40
		Y	G	SAND, GRAVEL, BOULDERS	40	60
		C		GUMBO CLAY	60	75
		Y	M	SILTY SAND @ GRAVEL	75	160
	N	S	G	FINE SAND, GRAVEL	160	185

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	A53B P.E. 18.97 SEAMLESS SAWHILL	Surface	181
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	CONT SLOT S.S.	181	185

7. Grout or Other Sealing Material

Method

9. Static Water Level

145 ft. below ground surface

10. Pump Test

Pumping level 175 ft. below surface

Pumping at 20 GP for 2 Hrs.

Pumping Method ?

11. Well Is

16 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NONE ON PROPERTY

13. Constructor / Supervisory Driller	Lic #	Date Signed
PR		01-27-1992
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JR		01-27-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		15	Septic or Holding, or POWTS Tank		90

Comment:

Created On: 04-23-1992 Updated On: 04-23-1992 Review Status: