

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EM909		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner DALE SANFORD						Phone #		1. Well Location				Fire # (if avail.)											
Mailing Address HC 1 BOX 444						Town of FLORENCE						Street Address or Road Name and Number											
City FLORENCE				State WI		Zip Code 54121																	
County Florence		Co. Permit #		Notification #		Completed 01-22-1992		Subdivision Name			Lot #		Block #										
Well Constructor (Business Name) ROMITTI JR, PETER				Lic. # 466		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code												
Address W8859 CNTY N NIAGARA WI 54151-9788				Well Plan Approval #		SE SW Section Township Range or Govt Lot # 26 39 N 18 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled															
				Approval Date (mm-dd-yyyy)																			
Hicap Permanent Well #		Common Well #		Specific Capacity 0.7		3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes Hicap Well ? No Hicap Property ? No Hicap Potable ?																	
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes																							
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method												8. Geology											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)							
6		Surface		185		Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)		S SAND Surface 30 Y SAND, GRAVEL 30 40 Y G SAND, GRAVEL, BOULDERS 40 60 C GUMBO CLAY 60 75 Y M SILTY SAND @ GRAVEL 75 160 N S G FINE SAND, GRAVEL 160 185		145 ft. below ground surface Pumping level 175 ft. below surface Pumping at 20 GP for 2 Hrs. Pumping Method ?		16 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes											
6		A53B P.E. 18.97 SEAMLESS SAWHILL		Surface										181									
Dia. (in.)		Screen type, material & slot size		From (ft.)										To (ft.)									
6		CONT SLOT S.S.		181										185									
6. Casing, Liner, Screen Dia. (in.) Material, Weight, Specification Manufacturer & Method of Assembly From (ft.) To (ft.) 6 A53B P.E. 18.97 SEAMLESS SAWHILL Surface 181														9. Static Water Level				11. Well Is					
7. Grout or Other Sealing Material Method														12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? No NONE ON PROPERTY				13. Constructor / Supervisory Driller Lic # Date Signed PR 01-27-1992 Drill Rig Operator Lic or Reg # Date Signed JR 01-27-1992					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		15	Septic or Holding, or POWTS Tank		90

Comment:

Created On: 04-23-1992

Updated On: 04-23-1992

Review Status: