Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EM910

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JOHN RABIEGO			Phone #: (715)528-3039
Mailing Address: HC 1 BOX 273			
City: FLORENCE	State: WI	Zip Code: 54121	
County: Florence	Co. Permit #:	Notification #:	Completed: 03-04-1992

1. Well Location

Town of FERN

Fire # (if avail.):

Street Address or Road Name and Number: PATTON LAKE RD

Subdivision Name: | Lot #: | Block #:

Well Constructor (Business Name): ROMITTI JR, PETER	Lic. #: 466	Facility ID # (Public Wells):	Latitude / Longitude in Decimal Degree (DD): °N °W
Address: W8859 CNTY N NIAGARA WI 54151-9788		Well Plan Approval #:	Method Code:
		Approval Date (mm-dd-yyyy):	

SE NW or Govt Lot #	Section: 20	Township: 39 N	Range: 17 E

2. Well Type New Well

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?

Construction Type: Drilled

Hicap Permanent Well #	Common Well #	Specific Capacity: 0.2

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	124

Upper Enlarged Drillhole / Lower Open Bedrock

Yes Rotary - Air .....

Rotary - Mud Circulation .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Y		SAND @ GRAVEL	Surface	40
	H	G	M	SILTY GRAVEL, HARD PACKED	40	115
		Y		SAND @ GRAVEL	115	124

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	P.E. A53B 18.97#/FT SAWHILL	Surface	120
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	S.S. K-PACKER	120	124

9. Static Water Level

98 ft. below ground surface

10. Pump Test

Pumping level 118 ft. below surface

Pumping at 4 GP for 2 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
PR		03-05-1992
Drill Rig Operator	Lic or Reg #	Date Signed
JR		03-05-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		40	Septic or Holding, or POWTS Tank		100

Comment:

Created On: 04-23-1992 Updated On: 04-23-1992 Review Status: