

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EM911		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner EUGENE STEENO JR Phone # (715)251-4431						1. Well Location				Fire # (if avail.)							
Mailing Address 108 HILL ST						Town of NIAGARA				Street Address or Road Name and Number							
City NIAGARA				State WI		Zip Code 54151											
County Marinette		Co. Permit #		Notification #		Completed 04-22-1992		Subdivision Name			Lot #		Block #				
Well Constructor (Business Name) ROMITTI JR, PETER				Lic. # 466		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code					
Address W8859 CNTY N NIAGARA WI 54151-9788				Well Plan Approval #		NE SE		Section 20		Township 38 N		Range 20 E					
				Approval Date (mm-dd-yyyy)		or Govt Lot #		20		38 N		20 E					
Hicap Permanent Well #			Common Well #			Specific Capacity 1			2. Well Type New Well								
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No		Reason for replaced or reconstructed well ?									
						Hicap Property ? No											
Hicap Potable ?						Construction Type Drilled											
						4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method												8. Geology					
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock						Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)				
6 Surface 73			Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)						Q S		CAVING BROWN SAND		Surface 25				
									V G		SAND, GRAVEL, BOULDERS		25 35				
									S		SAND		35 40				
									Y G		SAND, GRAVEL, BOULDERS		40 50				
									C		CLAY		50 55				
									S M		SILTY SAND		55 60				
6 S.S. CONT SLOT			Y		SAND @ GRAVEL		60 73										
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)		40 ft. below ground surface				14 in. above grade					
6		P.E, SEAMLESS, A53-B 18.97 LB/FT SAWHILL				Surface 70		10. Pump Test Pumping level 55 ft. below surface Pumping at 15 GP for 3 Hrs. Pumping Method ?				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.) To (ft.)						Disinfected ? Yes					
6		S.S. CONT SLOT				73		Capped ? Yes									
7. Grout or Other Sealing Material Method												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? NONE ON PROPERTY					
								13. Constructor / Supervisory Driller		Lic #		Date Signed					
								PR				04-25-1992					
								Drill Rig Operator		Lic or Reg #		Date Signed					
								BD				04-25-1992					

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 06-01-1992

Updated On: 06-01-1992

Review Status: