Well Construction Report
WISCONSIN UNIQUE WELL NUMBER EM911

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: EUGENE STEENO JR			Phone #: (715)251-4431
Mailing Address: 108 HILL ST			
City: NIAGARA	State: WI	Zip Code: 54151	
County: Marinette	Co. Permit #:	Notification #:	Completed: 04-22-1992

Well Constructor (Business Name): ROMITTI JR, PETER	Lic. #: 466	Facility ID # (Public Wells):	
Address: W8859 CNTY N NIAGARA WI 54151-9788		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1	

1. Well Location

Town of NIAGARA

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name:	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): °N °W			Method Code:
NE SE or Govt Lot #:	Section: 20	Township: 38 N	Range: 20 E

2. Well Type New Well

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	73

Upper Enlarged Drillhole / Lower Open Bedrock

Yes Rotary - Air .....

Rotary - Mud Circulation .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	Q	S		CAVING BROWN SAND	Surface	25
		V	G	SAND, GRAVEL, BOULDERS	25	35
		S		SAND	35	40
		Y	G	SAND, GRAVEL, BOULDERS	40	50
		C		CLAY	50	55
		S	M	SILTY SAND	55	60
		Y		SAND @ GRAVEL	60	73

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	P.E, SEAMLESS, A53-B 18.97 LB/FT SAWHILL	Surface	70
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	S.S. CONT SLOT		73

9. Static Water Level

40 ft. below ground surface

10. Pump Test

Pumping level 55 ft. below surface

Pumping at 15 GP for 3 Hrs.

Pumping Method ?

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

NONE ON PROPERTY

13. Constructor / Supervisory Driller	Lic #	Date Signed
PR		04-25-1992
Drill Rig Operator	Lic or Reg #	Date Signed
BD		04-25-1992

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 06-01-1992 Updated On: 06-01-1992 Review Status: