

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				EN047		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A						
Property Owner JIM DARBY					Phone # (715)635-3115		1. Well Location				Fire # (if avail.)					
Mailing Address HCR 58							Town of SCOTT									
City SPOONER					State WI		Zip Code 54871									
County Burnett		Co. Permit #		Notification #		Completed 04-24-1992		Subdivision Name				Lot # Block #				
Well Constructor (Business Name) BEECROFT, ROGER					Lic. # 182		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code			
Address RT 1 BOX 91BB SHELL LAKE WI 54871-9801					Well Plan Approval #		Approval Date (mm-dd-yyyy)		or Govt Lot # 006		Section 24		Township 40 N		Range 14 W	
Hicap Permanent Well #			Common Well #			Specific Capacity 1.5			2. Well Type New Well				of previous unique well # constructed in			
3. Well serves 1 # of Private, potable					Hicap Well ? No			Hicap Property ? No			Reason for replaced or reconstructed well ?					
Heat Exchange ___ # of drillholes					Hicap Potable ?			Construction Type Drilled								
4. Potential Contamination Sources - ON REVERSE SIDE																
5. Drillhole Dimensions and Construction Method																
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock						
5		Surface		58												
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)										
8. Geology																
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)						
P				HARDPAN				Surface		15						
G C				GRAVEL @ CLAY				15		47						
S				SAND				47		58						
6. Casing, Liner, Screen																
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)								
5		NEW BLACK STEEL 15 LB A53B SAWHILL WELDED				Surface		54.5								
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)								
5		STAINLESS STEEL				54		58								
9. Static Water Level																
22 ft. below ground surface										11. Well Is						
10. Pump Test										12 in. above grade						
Pumping level 35 ft. below surface										Developed ? Yes						
Pumping at 20 GP for 1 Hrs.										Disinfected ? Yes						
Pumping Method ?										Capped ? Yes						
7. Grout or Other Sealing Material																
Method																
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement								
BENTONITE GRANULARS				Surface		0										
12. Notified Owner of need to fill & seal ?																
Filled & Sealed Well(s) as needed?																
13. Constructor / Supervisory Driller										Lic #		Date Signed				
RB												05-04-1992				
Drill Rig Operator										Lic or Reg #		Date Signed				
RB																

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		10

Comment:

Created On: 06-09-1992

Updated On: 06-09-1992

Review Status: